Weekly circulation digital programming thermostat with LCD touch screen, which has 6-event everyday. Manual mode and programme mode could be selected The thermostat is recommended for control of electric heating devices or on/off valve actuator used in hydronic floor heating.

### Selection Table:

Model	Current	Application				
E92. 713	3A	Built-in&floor sensor,floor limit sensor weekly programme				
E92.723	3A	Built-in&floor sensor,floor limit sensor weekly programme,a potential-free output				
E92.716		Built-in&floor sensor,floor limit sensor weekly programme				

### Parameter:

Voltage:220V/230V

Power comsuption:2W Setting range:5~90°C (can adjust to 35-90°C)

Limitation setting:5...60 ℃

(Factory setting:35°C)

Switch differential: 0.5-10? adjustable factory setting1°C

Ambient temperature:-5~50°C Protective houseing:IP20

Housing material: anti-flammable PC

☼ Wake-up, event 1

Manual mode

Clock-controlled

programme mode

1 Leave(am), event 2

Heating on

Function:

Return(am), event 3

Leave(pm), event 4

↑ Return(pm), event 5

( Sleep, event 6

## User operation:

- 1) On/Off " (b "
- 2) At clock-controlled programme mode, press \* ▲ "or" ▼ " enter to temporary control.
- 3) UP" ▲ ".DOWN" ▼ "to adjust the temperature value.
- 4) Press clock "O"key for 5 seconds, then enter to clock set. choose modified item by pressing clock" (9 ".press
- UP/DOWN" ▲▼ "to modify the date and clock, then switch off to quit.
- 5) Press menu" ( "to choose manual mode or programme mode.
- 6) Set temperature and clock display alternately, room temperature can be read out directly.
- 7) Press both "▲ "" ▼ "for five seconds to engage/dise-ngage key-lock function key-lock shows" a "
- (" a "this symbol dispeared that shows unlock)

1) The pre-programmed setpoint(15°C) for event 3&4 is the same as event 2,please reset it according to your individual requirement. 2)Symbol "OFF" will be displayed if the setpoint reaches the

### Advanced setting(qualified person preferred):

Usually finished at mounting thermostat.

Press kev simultaneously press power on key when in power off.

# Programming:

Press Menu key for 5 seconds to start programming

Key Eve		nt	Symbol	Time		Modify	Temp.	Modify	
		1	<b>‡</b>	06:	00	Δ		Δ	
	Day 1-5	2	<b>□</b> +	08:	00	∇ 15℃ Event 15℃ Time 22℃ 15℃ 22℃	$\nabla$		
		3	₩•	11:	30		15℃		
		4	<b>₩</b>	12:	30		15℃	Temp.	
		5	Ûŧ	17:	00		22℃	remp.	
		6	Q	22:	00		15℃		
	Day 6-7	1	✡	08:	00		22℃		
		2	a	23:	00		15℃		

minimum set value and the thermostat is switch off in this event.

5LTP:Start anti-frozen function in power off Press + or - key to change the present antifrozen function

Re-press menu key to enter to next step.



1ADJ:Temperature calibration

Press + or - key to adjust present checked value.adiustable scale:9.9℃.

Re-press menu key to enter to next step.

## 2SEN:Sensor mode

Press + or - key to choose senor working mode IN:built-in, OUT: floor\_sensor.

ALL:both sensors.floor sensor is the limit sensor Re-press menu key to enter to next step.



25 FN

3LIT: Modify limition value Press + or - key to modify the temp. Limit valuelimition range:5~60°C Re-press menu key to enter to next step.

4DIF:Switch differential setting Press + or - key to change switch defferential Setting range: 0.5~10°C.

Re-press menu key to enter to next step.



60 - 6

Press + or - to choose day off 5/2 day mode.6/1day mode.7 day mode Re-press menu key to enter to next step. 7RLE:Potential-free output and main

power output in same/different way. Press + or - key to change the present linkage state.

6PRG:Set day off mode

00:in same way, 01:in defferent way Re-press menu key to enter to next step.

8DLY:Delay time of potential-free output Press + or - key to change linkage delay time Range:0-5min.

Re-press menu key to enter to next step.

9HIT:Max. Temperature setting Press + or - key to change the Max.value Range:35-90°C Re-press menu key to enter to next step.


> AFAC:Reset to factory setting Press + key for 5seconds till showing ---Reset to factory setting Swithch off for saving setting


HVAC CONTROLS PRODUCTS DS/MRD-06-091124

### Sensor Failure

E0:Built-in sensor short-circuited or disconnected E1:Exernal sensor short-circuited or desconnected. When shows E0/E1 error thermostat must be checked till the error is eliminated


## Display symbols






# Mounting steps:


Release the front cover by inserting a screwdrive into bottom crack.




Take the backing plate apart according to the 2 following diagram.



Mounted the backing plate in the wall socket by 3 Mounted the screwdriver.




After connect wires(see right diagram), the themostat mounte on the backing plate and remounted the cover and frame.





# Connecting Diagram

### Attention:

The thermostat which connect the electric heating device is apply to full load(3200W) heating cable in 2500m height above sea level, and the rated power of external load should be less than or equal to 80% rated power thermostat when in the 2500m to 4200m height.







DS/MRD-06-091124 HVAC CONTROLS PRODUCTS